

DOORS						
SPACE	DOOR TYPE	DOOR LOCK FUNCTION	LOCK TYPE	FIRE / ACCOUSTIC RATED	FRAME TYPE	GLAZING
Building Entry	Bi-parting sliding automatic glazed doors(min two leaves)	Automatic on BMS and /or swipe access				Fully Glazed Doors
Enclosed Workspace/ Office	Solid core door	Entry door lockable.	Office lock	--		Glazed sidelight
Meeting Rooms / Seminar rooms	Solid door with glazed sidelight or half glazed	Not lockable	Passage latch			Glazed sidelight
Copy/Print Areas/	Half glazed door may be required for acoustic separation	Not lockable	Passage latch	Door may be required for acoustic separation with seals.		Half glazed door to circulation, if door provided
Comms Rooms	Solid core door	Entry Door Lockable with Swipe access	Storeroom lock		Steel Framed	
Toilets	Entry door solid core	Privacy Latch to individual cubicles. Privacy lock to single toilet rooms.	Privacy latch with indicator		Steel Framed	
Accessible Toilets	Entry door solid core	Accessible Privacy lock to AS1428	Accessible Privacy latch with indicator		Steel Framed	
Cleaners /Store Room	Solid core door	Entry door lockable.	Storeroom lock		Steel Framed	
First Aid Rooms	Min 1m wide, solid core door with viewing panel	Not lockable	Passage latch			Viewing panel to door or glazed side panel.
Tea Area /lunch rooms	Solid core door Required to provide Acoustic separation to adjacent spaces	Not lockable	Passage latch			Viewing Panel to door or Glazed Side Panel.
Tutorial Rooms	Half glass door to circulation area. An acoustic operable wall between Tutorial rooms may be Included - refer to project brief.	Entry door to be auto opening with Cardex swipe to outside and lever exit handle internal	Classroom lock with Cardex Or Classroom lock- (if manual operation requested in brief)	-		Half glazed door to circulation
Theatres / theatrettes	Minimum 1m clear solid core doors to circulation and exit door to outside.	Entry door to be auto opening with Cardex swipe to outside and lever exit handle internal	Classroom lock with Cardex And panic bars	Solid door with acoustic seals.— Fire rated if required by legislation	Steel framed	Viewing panel to circulation zone 125mm wide by 700mm high with sill at 1100mm

	DOORS					
SPACE	DOOR TYPE	DOOR LOCK FUNCTION	LOCK TYPE	FIRE / ACCOUSTIC RATED	FRAME TYPE	GLAZING
Laboratories	Entry door half glazed solid core. Door between Laboratory and Preparation to be solid core with viewing panel	Entry door to be auto opening with Cardex swipe to outside and leaver exit handle internal	Classroom lock with Cardex -	-		Half glazed entry door. Glazed panels to Preparation room, 125mm wide by 600mm high with sill at 1200mm
Lab Prep rooms	Solid core entry door with viewing panel.	Entry door lockable.	Classroom lock			Glazed panels to Preparation room, 125mm wide by 600mm high with sill at 1200mm
Damp & Wet Laboratory	External door solid core. Door between Laboratory and Preparation to be solid core with glazing panel. Internal half glazed doors to adjacent areas.	Entry door to be auto opening with Cardex Swipe to outside and leaver exit handle internal	Classroom lock with Cardex --	-		Half glazed entry door. Glazed panels to Preparation room, 125mm wide by 600mm high with sill at 1200mm
Chemical Store	Outward opening fire rated door	Entry door Lockable.	Classroom lock	Fire rated door (FRL -- /120/30)	Fire rated steel frame	
Open Stairway between zones/departments	Door may be required for acoustic separation Zone dependant					
General Use Fire Stairs	Doors to be on hold open devices if required to be Fire rated	Internal door not lockable External door lockable with electric strike	Passage latch to internal doors. Storeroom lock to external doors.	Fire rated door To BCA requirements	Fire rated steel Frame	
Fire Stairs	Fire rated Solid doors	Internal door not lockable External door lockable with electric strike	Passage latch to internal doors. Storeroom lock to external doors.	Fire rated door To BCA requirements	Fire rated steel Frame	
Plant Rooms	Fire rated /acoustic doors as required. Louvre doors where external	Lockable	Storeroom lock	Fire rated door if required to BCA requirements	Steel framed or aluminium framed	